

Candia, Town

Above Ground Propane Tank

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-115AT

Date of Issue

4/29/2024

Expiration Date

4/29/2025

Owner: PETRAITIS, RONALD B. & SUSAN K.

Applicant: PALMER GAS CO.

Location of Work: 193 CROWLEY ROAD
(No. and Street) (Unit or Building)

Description of Work: INSTALL 2- 120 GAL PROPANE TANKS ONLY

ZONING DATA: District: RES Map/Lot: 414-152-7

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: PALMER GAS CO. 898 7986

REMARKS:

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.
TANKS MUST BE LISTED, LABELED AND HAVE UPDATED DATE CODES.
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.
BACK FILL WITH CLEAN MATERIAL.
LINE SETS MUST HOLD 15 LB FOR 10 MIN.
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Permit Holder: PALMER GAS CO.
(Taking Responsibility for the Work)
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0 Permit Fee: \$100.00 Check No.: 22991 Cash: \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction

Aut Donnan 2
Code Official Date: 04/29/2024