

Candia, Town  
**GENERATOR PERMIT**

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015  
Inspections - Mon, Tues & Thurs afternoons

**Permit Number**  
2024-128PE  
**Date of Issue**  
5/09/2024  
**Expiration Date**  
5/09/2025

**Owner:** FLEMING, PAUL & LESLIE TRUSTEES 32 PALMER RD REALTY TRUST

**Applicant:** SANFORD TEMPERTURE CONTROL

**Location of Work:** 32 PALMER ROAD  
(No. and Street) (Unit or Building)

**Description of Work:** REPLACE GENERATOR ONLY

**ZONING DATA:** District: RES Map/Lot: 414-051

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:  
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:  
**Building / Addition:** Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

**REMARKS:**


**BACKUP ELECTRIC GENERATOR**

- ELECTRIC CONNECTIONS MUST BE COMPLETED BY A KNOWLEDGABLE INDIVIDUAL IN CONFORMANCE CURRENTLY ADOPTED ELECTRIC CODES.
- AN ELECTRIC PERMIT MUST BE OBTAINED PRIOR TO PERFORMING ANY ELECTRIC WORK.
- LP GAS PIPING MUST BE INSTALLED AND CONNECTED BY A KNOWLEDGABLE INDIVIDUAL IN CONFORMANCE WITH NFPA 54 AND NFPA 37.
- A GAS PIPING PERMIT MUST BE OBTAINED PRIOR TO INSTALLING ANY GAS PIPING.
- IF GAS PIPING IS BURIED, INSPECTION IS REQUIRED PRIOR TO BACKFILLING.
- GENERATOR MUST BE LOCATED IN COMPLIANCE WITH STATE FIRE MARSHAL INFORMATION BULLETIN ON RESIDENTIAL GENERATOR SAFETY REVISED JUNE 22, 2009

**Permit Holder:** SANFORD TEMPERTURE CONTROL  
(Taking Responsibility for the Work)  
**Company/Affiliation:** Contractor **Job Site Phone Number:**

**Constr Cost:** \$0 **Permit Fee:** \$110.00 **Check No.:** 2804 **Cash:** \$0.00

**The Permit Card Shall be Posted and Visible From the Street During Construction**

  
**Code Official**

05-09-2024  
**Date**