

Candia, Town

GAS PIPING PERMIT

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number
2024-133GP

Date of Issue
5/13/2024

Expiration Date
5/13/2025

Owner: LEBLANC MIKE

Applicant: Wickson NRG LLC

Location of Work: 96 DEERFIELD ROAD
(No. and Street) (Unit or Building)

Description of Work: INSTALL APPROX 50 UNDERGROUND GAS PIPING

ZONING DATA: District: Map/Lot: 406-028

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Wickson NRG LLC 890-7051

REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: Wickson NRG LLC
(Taking Responsibility for the Work)
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0 Permit Fee: \$110.00 Check No.: 3105 Cash: \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official Date: 05-13-2024