

Candia, Town
Above Ground Propane Tank

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number
2024-141AT
Date of Issue
5/22/2024
Expiration Date
5/22/2025

Owner: COBURN, DONNA L, WRIGHT, DAVID

Applicant: PALMER GAS CO.

Location of Work: 300 PATTEN HILL ROAD
(No. and Street) (Unit or Building)

Description of Work: PLACE TWO 120 GAL PROPANE TANKS FOR GENERATOR AND COOKING

ZONING DATA: District: RES Map/Lot: 409-233-5

CONSTRUCTION DATA: Use Group: Min. Type Constr:
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: PALMER GAS CO. 898 7986


REMARKS:

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.
TANKS MUST BE LISTED, LABELED AND HAVE UPDATED DATE CODES.
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.
BACK FILL WITH CLEAN MATERIAL.
LINE SETS MUST HOLD 15 LB FOR 10 MIN.
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Permit Holder: PALMER GAS CO. (Taking Responsibility for the Work)	
Company/Affiliation: Contractor	Job Site Phone Number:

Constr Cost: \$0	Permit Fee: \$100.00	Check No.: 23095	Cash: \$0.00
-------------------------	-----------------------------	-------------------------	---------------------

The Permit Card Shall be Posted and Visible From the Street During Construction

 Code Official	<u>05-22-2024</u> Date
---	----------------------------------