

Candia, Town

# GAS PIPING PERMIT

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

**Permit Number**  
2024-153GP

**Date of Issue**  
6/06/2024

**Expiration Date**  
6/06/2025

**Owner:** FRISELLA FRED

**Applicant:** DEAD RIVER COMPANY

**Location of Work:** 38 LANDING WAY 406-140-22  
(No. and Street) (Unit or Building)

**Description of Work:** GAS PIPING FROM UG TANK TO GENERATOR

**ZONING DATA:** District: RES Map\Lot:

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:

**Design Occupant Load:** Total Number of Dwelling Units: 0 Construction Area:

**Building / Addition:** Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

**CONTRACTOR:** DEAD RIVER COMPANY (603) 625-8531

**REMARKS:**

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.  
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.  
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

**Permit Holder:** DEAD RIVER COMPANY  
(Taking Responsibility for the Work)  
**Company/Affiliation:** Contractor **Job Site Phone Number:**

**Constr Cost:** \$0 **Permit Fee:** \$110.00 **Check No.:** **Cash:** \$110.00

The Permit Card Shall be Posted and Visible From the Street During Construction

  
**Code Official** **06062024**  
Date