

Candia, Town  
**MECHANICAL WORK PERMIT**

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015  
Inspections - Mon, Tues & Thurs afternoons

**Permit Number**  
2024-155ME  
**Date of Issue**  
6/10/2024  
**Expiration Date**  
6/10/2025

**Owner:** MANNION THOMAS

**Applicant:** Panzieri Plumbing and Heating

**Location of Work:** 54 ISLAND ROAD  
(No. and Street) (Unit or Building)

**Description of Work:** REPLACE BOILER

**ZONING DATA:** District: RES Map\Lot: 407-006

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:  
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

**Building / Addition:** Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

**CONTRACTOR:** Panzieri Plumbing and Heating

**REMARKS:**

REFER TO THE "CANDIA VOLUNTEER FIRE DEPARTMENT GAS FIRED APPLIANCE CHECKLIST" FOR INSTALLATION REQUIREMENTS.

INSPECTION OF LISTED AND LABLE APPLIANCE IS REQUIRED WHEN INSTALLATION IS COMPLETE AND OPERATIONAL.

ALL LP GAS INSTALLATIONS MUST BE IN COMPLIANCE WITH NFPA 58 & 54.


ANY NEW GAS PIPING REQUIRES INSPECTED 5 LB GAUGE PRESSURE TEST PRIOR TO ENERGIZING.

CALL BUILDING DEPARTMENT TO SCHDUAL INSPECTIONS.

**Permit Holder:** Panzieri Plumbing and Heating  
(Taking Responsibility for the Work)  
**Company/Affiliation:** Contractor **Job Site Phone Number:**

**Constr Cost:** \$0 **Permit Fee:** \$110.00 **Check No.:** 729 **Cash:** \$0.00

**The Permit Card Shall be Posted and Visible From the Street During Construction**

  
Code Official

06-10-2024  
Date