

Candia, Town
FUEL OIL TANK
Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number
2024-161FT
Date of Issue
6/11/2024
Expiration Date
6/11/2025

Owner: SAMOWITZ & KLEIN CANDIA, LLC C/O FERNE SAMOWITZ
Applicant: RICK WENZEL OIL COMPANY, LLC
Location of Work: 115 RAYMOND ROAD
(No. and Street) (Unit or Building)

Description of Work: REPLACE 2- 275 GAL OIL TANKS

ZONING DATA: District: RES Map\Lot: 409-193-2

CONSTRUCTION DATA: Use Group: Min. Type Constr:
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:
Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: RICK WENZEL OIL COMPANY, LLC 603-673-9554

REMARKS:

1. FUEL OIL STORAGE TANKS SHALL BE LISTED AND LABELLED FOR SPECIFIED USE.
2. FUEL TANK SHALL BE INSTALLED IN COMPLIANCE WITH APPLICABLE NFPA CODES.
3. PROPER SUPPORT IS REQUIRED AND MUST BE LOCATED NO LESS THAN 5 FEET FROM BURNER.
4. MINIMUM 1 1/4" VENT PIPE WITH ALARM IS REQUIRED.
5. FUEL OIL TANK SHALL BE SECURELY ANCHORED TO PREVENT FLOTATION. NONCOMBUSTIBLE STRAPS OR RIGID FASTENER TO THE TOP IS REQUIRED.
6. MAXIMUM TANK SIZE ALLOWED IS 330 GALLONS WITH A COMBINED STORAGE NOT TO EXCEED 660 GALLONS.
7. PROPER SPACING TO WINDOWS OR OTHER OPENINGS INTO BUILDING MUST BE MAINTAINED..
8. VENT PIPE MUST SLOPE DOWN TO TANK.
9. THERMAL AND MAMUAL FUEL SHUTOFF IS REQUIRED AT BOTTOM OF TANK AND AT BURNER.
10. CONTACT THIS OFFICE FOR INSPECTION WHEN WORK IS COMPLETE.

Permit Holder: RICK WENZEL OIL COMPANY, LLC
(Taking Responsibility for the Work)
Company/Affiliation: Contractor **Job Site Phone Number:**

Constr Cost: \$0 **Permit Fee:** \$100.00 **Check No.:** 1168 **Cash:** \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official

06-11-2024.
Date