

# TOWN OF CANDIA

## GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-295 Date: 09/04/2024  
Map: 000406 Lot: 000140 Sub Lot: 000021

Permit issued to: KLING BRUCE E & JACQUELINE M REV TRUST  
at: 64 LANDING WAY

Owner Address: 4 VILLAGE BROOK LANE DERRY, NH 03038 | Phone:

Applicant: KEVIN BELL | Phone:

Contractor: KEVIN BELL | Phone: | License #:


Permit Fee: \$180.00 | Estimated Cost: \$0

NOTE: GAS PIPING FOR NEW HOME

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015  
Building Inspector

NOTE: THIS PERMIT EXPIRES SEPTEMBER 04, 2025.