

TOWN OF CANDIA

GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-372 Date: 10/10/2024
Map: 000406 Lot: 000140 Sub Lot: 000021

Permit issued to: KLING BRUCE E & JACQUELINE M REV TRUST
at: 64 LANDING WAY

Owner Address: 4 VILLAGE BROOK LANE DERRY, NH 03038 | Phone:

Applicant: EASTERN PROPANE | Phone:

Contractor: EASTERN PROPANE | Phone: | License #:


Permit Fee: \$110.00 | Estimated Cost: \$0

NOTE: GAS LINE FROM UG PROPANE TANK TO HOUSE

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES OCTOBER 10, 2025.