



# TOWN OF CANDIA GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-379 Date: 10/17/2024  
Map: 000406 Lot: 000145 Sub Lot: 000000

Permit issued to: CRONIN, ROBERT BRENNAN JR & YVONNE M  
at: 157 CRITCHETT RD

Owner Address: 157 CRITCHETT ROAD CANDIA, NH 03034 | Phone:

Applicant: ROBERT CRONIN | Phone:

Contractor: ROBERT CRONIN | Phone: | License #:


Permit Fee: \$110.00 | Estimated Cost: \$0

NOTE: GAS PIPING TO BE DONE BY OWNER

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015  
Building Inspector

NOTE: THIS PERMIT EXPIRES OCTOBER 17, 2025.