



TOWN OF CANDIA

GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-401 Date: 10/24/2024
Map: 000409 Lot: 000056 Sub Lot: 000000

Permit issued to: HEFFERNAN,EDMUND T.&MARYCLARE
at: 14 STUMP ST

Owner Address: 14 STUMP ST - PO BOX 245 CANDIA, NH 03034 | Phone:

Applicant: JN ELECTRIC LLC | Phone:

Contractor: JN ELECTRIC LLC | Phone: | License #:

Permit Fee: \$110.00 | Estimated Cost: \$0

NOTE: GAS LIN FOR NEW 18KW GENERATOTR

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES OCTOBER 24, 2025.