



TOWN OF CANDIA GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-420 Date: 11/05/2024
Map: 000409 Lot: 000141 Sub Lot: 000000

Permit issued to: SEVERINO THOMAS
at: 80 DIAMOND HILL RD


Owner Address: 92 ADAMS ROAD CANDIA, NH 03034 | Phone:
Applicant: LEGENDARY PLUMBING AND HEATING | Phone:
Contractor: LEGENDARY PLUMBING AND HEATING | Phone: | License #:
Permit Fee: \$110.00 | Estimated Cost: \$0

NOTE: GAS PIPING FOR HOME RENOVATIONS

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES NOVEMBER 05, 2025.