



TOWN OF CANDIA

FUEL OIL TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-435 Date: 11/12/2024
 Map: 000405 Lot: 000057 Sub Lot: 000001

Permit issued to: STRIBLING, LAIRD A
 at: 591 HIGH ST

Owner Address: 591 HIGH STREET CANDIA, NH 03034 | Phone:


Applicant: PATRIOT HEATING & COOLING LLC | Phone:

Contractor: PATRIOT HEATING & COOLING LLC | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: REPLACE 275 GAL OIL TANK

1. FUEL OIL STORAGE TANKS SHALL BE LISTED AND LABELLED FOR SPECIFIED USE.
2. FUEL TANK SHALL BE INSTALLED IN COMPLIANCE WITH APPLICABLE NFPA CODES.
3. PROPER SUPPORT IS REQUIRED AND MUST BE LOCATED NO LESS THAN 5 FEET FROM BURNER.
4. MINIMUM 1 1/4" VENT PIPE WITH ALARM IS REQUIRED.
5. FUEL OIL TANK SHALL BE SECURELY ANCHORED TO PREVENT FLOTATION. NONCOMBUSTIBLE STRAPS OR RIGID FASTENER TO THE TOP IS REQUIRED.
6. MAXIMUM TANK SIZE ALLOWED IS 330 GALLONS WITH A COMBINED STORAGE NOT TO EXCEED 660 GALLONS.
7. PROPER SPACING TO WINDOWS OR OTHER OPENINGS INTO BUILDING MUST BE MAINTAINED..
8. VENT PIPE MUST SLOPE DOWN TO TANK.
9. THERMAL AND MAMUAL FUEL SHUTOFF IS REQUIRED AT BOTTOM OF TANK AND AT BURNER.
10. CONTACT THIS OFFICE FOR INSPECTION WHEN WORK IS COMPLETE.

Signed:  Telephone: (603) 483-1015
 Building Inspector

NOTE: THIS PERMIT EXPIRES NOVEMBER 12, 2025.