

TOWN OF CANDIA PROPANE TANK PERMIT



The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-457 Date: 11/21/2024
Map: 000411 Lot: 000002 Sub Lot: 000000

Permit issued to: 16 COLLENY DRIVE LLC
at: 205 TOWER HILL RD

Owner Address: 1662 ELM STREET MANCHESTER, NH 03101 | Phone:

Applicant: PHIL LEMIRE | Phone:

Contractor: PHIL LEMIRE | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: INGROUND 1000 GAL PROPANE TANK

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.


TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES NOVEMBER 21, 2025.