

TOWN OF CANDIA

PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-495 Date: 12/17/2024
Map: 000406 Lot: 000166 Sub Lot: 000000

Permit issued to: KELLY BARBARA J REVOCABLE TRUST
at: 55 OLD DEERFIELD RD

Owner Address: 55 OLD DEERFIELD ROAD CANDIA, NH 03034 | Phone:

Applicant: BUXTON OIL | Phone:

Contractor: BUXTON OIL | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: PLACE 2-120 GAL PROPANE TANKS FOR GENERATOR

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.

TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed: _____



Building Inspector

Telephone: _____

(603) 483-1015

NOTE: THIS PERMIT EXPIRES DECEMBER 17, 2025.