

# TOWN OF CANDIA

## PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-496 Date: 12/17/2024  
Map: 000402 Lot: 000066 Sub Lot: 000006

Permit issued to: CROSS-POWERS, MARK S & KARIN L  
at: 49 MAYHEW DR

Owner Address: 49 MAYHEW DRIVE CANDIA, NH 03034 | Phone:

Applicant: BUXTON OIL | Phone:

Contractor: BUXTON OIL | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: PLACE 2-120 GAL PROPANE TANKS FOR GENERATOR

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.


TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

GALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed:  Telephone: (603) 483-1015  
Building Inspector

NOTE: THIS PERMIT EXPIRES DECEMBER 17, 2025.