

TOWN OF CANDIA

PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-500 Date: 12/30/2024
Map: 000409 Lot: 000141 Sub Lot: 000000

Permit issued to: KLING BRIAN & RACHEL
at: 80 DIAMOND HILL RD

Owner Address: 4 VILLAGE BROOK LANE DERRY, NH 03038 | Phone:

Applicant: IRVING OIL | Phone:

Contractor: IRVING OIL | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: INSTALL 60 GAL PROPANE TANK FOR COOKING

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.


TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

GALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES DECEMBER 30, 2025.