



TOWN OF CANDIA PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2025-014 **Date:** 01/09/2025
Map: 000405 **Lot:** 000026 **Sub Lot:** 000001

Permit issued to: BOND, TIMOTHY E. & LINDA M.
at: 406 HIGH ST

Owner Address: 13 LANTERN DRIVE SANDOWN, NH 03873 | Phone:

Applicant: IRVING OIL | Phone:

Contractor: IRVING OIL | Phone: | License #:

Permit Fee: \$100.00 | **Estimated Cost:** \$0

NOTE: INSTALL A 500 GAL UNDER GROUND PROPANE TANK

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.


TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed:  **Telephone:** (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES JANUARY 09, 2026.