



TOWN OF CANDIA

GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2025-015 **Date:** 01/09/2025
Map: 000405 **Lot:** 000026 **Sub Lot:** 000001

Permit issued to: BOND, TIMOTHY E. & LINDA M.
at: 406 HIGH ST

Owner Address: 13 LANTERN DRIVE SANDOWN, NH 03873 | Phone:

Applicant: IRVING OIL | Phone:

Contractor: IRVING OIL | Phone: | License #:


Permit Fee: \$110.00 | Estimated Cost: \$0

NOTE: GAS PIPING FROM NEW TANK TO HOME

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES JANUARY 09, 2026.