

TOWN OF CANDIA

GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2025-018 Date: 01/14/2025
Map: 000402 Lot: 000066 Sub Lot: 000006

Permit issued to: CROSS-POWERS, MARK S & KARIN L
at: 49 MAYHEW DR

Owner Address: 49 MAYHEW DRIVE CANDIA, NH 03034 | Phone:

Applicant: BUXTON OIL & PROPANE | Phone:

Contractor: BUXTON OIL & PROPANE | Phone: | License #:

Permit Fee: \$110.00 | Estimated Cost: \$0

NOTE: RUN UNDERGROUND GAS LINE FROM PROPANE TANK TO GENERATOR

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:



Building Inspector

Telephone:

(603) 483-1015

NOTE: THIS PERMIT EXPIRES JANUARY 14, 2026.