TOWN OF CANDIA

74 HIGH STREET CANDIA, NH 03034

GAS PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number:		2025-067		Date:	03/19/2025
Мар:	000405	Lot:	000002	Sub Lot:	000001
— Permit issu	ed to: CANDIA MAS	ONIC TEMPLE A	SSOCIATION		
at: 12 SOUT	TH RD				
Permission	to: INSTALL 1- 120 (GALLON LP TAN	K FOR COOKING TO	REPLACE AMERIGA	us .
Owner Addi	ress: 240 RAYMOND	ROAD CANDIA	, NH 03034 Phone:	9788368497	
	CONTRACTOR Phon				
	RICHARD S RUSHTO		987986 License #: (GFE0801243	
Permit Fee:	\$100.00 Estimated	Cost: \$100			
+ NICDA 64	l manufina that appli	anaga that ara	not roted for the to	eting pressures he d	lisconnected from the

Signed: Telephone: (603) 483-1015

Building Official

If you are uncertain of the required inspections for your project please reach out to the Candia Building Department for clarification.

Printed: 3/19/2025 11:18:19AM Page 1 of 1

^{*} NFPA 54 requires that appliances that are not rated for the testing pressures be disconnected from the piping that is placed under pressure.